
Addendum #2

Date: 7/25/2019

Project: MILWAUKEE PUBLIC LIBRARY GOOD HOPE MILL ROAD

Proj. #: 170044.00

From: Zimmerman Architectural Studios, Inc.

To: Signage Manufacturer

This Addendum is issued to modify, explain, and amend the originally issued Specifications and Drawings dated 6/10/2019 and is hereby made a part of the Contract Documents. Please acknowledge receipt of this Addendum.

PLEASE INSERT THIS ADDENDUM IN THE DOCUMENT SET

QUESTIONS FROM BIDDERS:

1. Can we substitute 1/4" thick clear acrylic for the glass? We did this on the MPL main branch a few years back.



ZAS Response: The library approves of either glass or acrylic especially since other branches have used the glass.

2. For the window sign types (J, J.1, and N) can we use our FullView product? We have used this on 3 or 4 other MPL projects and they were well received.





ZAS Response: Product approved for use

3. Can we use our flatbed printing technology to print the laminate background onto painted acrylic (we do a high-res scan of the laminate), rather than laminate the material onto acrylic? The edges of the laminate do not look great, but if we print the image, you won't have the unfinished edges. Here is an image of a sign with a printed laminate top insert.



ZAS Response: The library approves of this alternative option keeping—the library prefers the most durable, aesthetically pleasing, and cost effective option.

4. Would you accept an integral, standard color vinyl instead of painted? One that would be a close match to the paint? Its more durable than painted vinyl.

ZAS Response: Yes-product approved

- End of Addendum #2

